

PRODUCT INFORMATION**ASHCROFT DIAPHRAGM SEALS
ON CHLORINE APPLICATIONS**

Halocarbon fill fluid must be used on all chlorine applications. If the process media includes chlorine in any form, Halocarbon is required. Examples are:

Chlorine (Dry)
Chlorine (Moist)
Chlorine Vapors
Chlorine Dioxide
Chlorine Trifluoride
Etc.

If a liquid filled gauge is attached to the seal, the fill fluid must again be Halocarbon.

Consult corrosion data guide for material recommendations. If chemicals are not listed, consult Customer Service at 203-378-8281.