



# Certificate / Certificat Zertifikat / 合格証

ASH 1207077 C001

*exida* hereby confirms that the:

## A-Series Pressure Switch

**Ashcroft Inc.**

**Stratford, CT - USA**

The manufacturer  
may use the mark:



Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A Element**

**SIL 1 @ HFT=0; SIL 2 @ HFT = 1; Route 1<sub>H</sub>**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFD<sub>AVG</sub> and Architecture Constraints  
must be verified for each application**

### Safety Function:

The A-Series Switch will de-energize the associated circuit when the trip pressure is reached. The de-energized switch position is with the NC switch contact open on a high pressure trip, or the NO switch contact open on a low pressure trip.

### Application Restrictions:


The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

Revision 4.0 November 25, 2019

Surveillance Audit Due  
December 1, 2022



  
Evaluating Assessor

  
Certifying Assessor

ASH 1207077 C001

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A Element**

**SIL 1 @ HFT=0; SIL 2 @ HFT = 1; Route 1<sub>H</sub>**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFD<sub>AVG</sub> and Architecture Constraints  
must be verified for each application**

**Systematic Capability :**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints for each element. This element meets *exida* criteria for Route 2<sub>H</sub>.

**IEC 61508 Failure Rates in FIT\***

Single Switch		$\lambda_{SD}$	$\lambda_{su}$	$\lambda_{DD}$	$\lambda_{DU}$	#
S-1	High Trip	0	26	0	89	67
	Low Trip	0	88	0	51	50
S-2	High Trip	0	24	0	68	65
	Low Trip	0	70	0	48	48
BV-1	High Trip	0	24	0	128	290
	Low Trip	0	100	0	78	273
BV-2	High Trip	0	24	0	139	309
	Low Trip	0	100	0	88	292
BV-3	High Trip	0	24	0	173	279
	Low Trip	0	130	0	92	262

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>AVG</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** ASH 16/02-007 R002 V2,R1 (or later)

**Safety Manual:** I&M009-10210

\* FIT = 1 failure / 10<sup>9</sup> hours

A-Series Pressure  
Switch



80 N Main St  
Sellersville, PA 18960