

June 23, 2021

Attention: Jeremy M. Payne ASHCROFT INC 250 EAST MAIN STREET STRATFORD, CT 06614

The design submission, tracking number 2021-02831, originally received on May 24, 2021 was surveyed and accepted for registration as follows:

CRN :	0F14836.52		Accepted on: June 23, 2021
Reg Type:	RENEWAL		Expiry Date: March 09, 2031
Drawing No. :	SOR-A-SERIES REV.1, PRP	03-AC-PS REV.2	As Noted
Fitting type:	A-SERIES PRESSURE SWIT	TCHES	
Description		MAWP	Design Temperature
See Scope o	f Registration		

The registration is conditional on your compliance with the following notes:

As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction is ASME B31.3.

It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.
This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.

- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.

- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3306 or fax (780) 437-7787 or e-mail Wangi@absa.ca.

Sincerely,

WANG, IAN, P. Eng. DOP Cert. No. D00009643



the pressure equipment safety authority AB-41 2019-08

STATUTORY DECLARATION Registration of Fittings

Single or Multiple Fitting Designs within one Fitting Category

I,	Jeremy Payne	Materials and test engineer manager	In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.
	(name of applicant)	(position title) (must be in a position of authority)	
of	Ashcroft, Inc.		
	(name	e of manufacturer)	
locat	ed at 250 East Main Street, Str	atford, CT 06614-5145, USA	litusi the shield."
	(pl	ant address)	
do so	plemnly declare that the fittings listed	hereunder, which are subject to the Safety Co	odes Act
(sele	ct only one)		
	comply with the requirements of _		ecifies the dimensions,

materials of construction, pressure/temperature ratings and identification marking of the fittings, or

are not covered by the provisions of a recognized North American standard and are therefore

manufactured to comply with	ASME B31.3 - 2020	as supported by the
. ,	title of code of construction or other applicable document	;)

attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the identification marking of the fittings.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified as described in the below Table as being suitable for the manufacturing of these fittings to the stated standard, regulation, code, guideline or other applicable document. The fittings covered by the declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

Quality Program Verification and Manufacturing Sites

A copy of the Quality Certificate from each manufacturing site must be included

ltem #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	\$OR-A-SERIES-REV1	ISO 9001:2015	see qa cert	2021-01-31	LLoyd's Register	see qa cert.
2.						

2021-02831

Aberta Municipal Affairs



In support of this application, the following information, calculations and/or test data are attached:

PRP03-AC-PS, Rev. 2; SOR-A-Series, Rev. 1, (CRN 0F14836.52 renewal) based on CRN 0F14836.5R1 renewal

	(Signature of the Declarer)		June 23, 2021 (Date)
	,		
DECLA	RED before me at in	the	of
	(city)		(province, territory, or state)
his	day of	_ ,	
	(Month)		(Year)
print)_	() which a start of Ortho or Natory Dublic)		
	(a Commissioner of Oaths or Notary Public)		DUE TO COVID NOTARIZATION IS NOT POSSIE
sign) _			
•	(a Commissioner of Oaths or Notary Public)		
_			
	(expiry date (mm/dd/yy))		
Commis	sioner of Oaths / Notary Public in and for:		
	-		(province, territory, or state)
	·		
To the meets	best of my knowledge and belief, the appli the requirements of the Safety Codes Act a	cation and CS	A
To the meets Standa	best of my knowledge and belief, the appli- the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted	cation and CS d for	A
To the meets Standa registra	best of my knowledge and belief, the appli the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS d for	A
To the meets Standa registra	best of my knowledge and belief, the appli- the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA
To the meets Standa registra	best of my knowledge and belief, the appli the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52
To the meets Standa registra	best of my knowledge and belief, the applie the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS. d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for
To the meets Standa registra CRN: _	best of my knowledge and belief, the applie the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS. d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration
To the meets Standa registra CRN: _	best of my knowledge and belief, the appli- the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By:
To the meets Standa registra CRN:_ Registe Expiry	best of my knowledge and belief, the applie the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category ered Date: Date:	cation and CS. d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By:
To the meets Standa registra CRN:_ Registe Expiry	best of my knowledge and belief, the applie the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category ered Date: Date:	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By: IAN WANG, P. Er
To the meets Standa registra CRN:_ Registe Expiry Signate	best of my knowledge and belief, the applie the requirements of the Safety Codes Act a and B51, Part 1, Clause 4.2, and is accepted ation in Category ered Date: Date: Ure:	cation and CS. d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By: IAN WANG, P. Er This stamp and signature have been affixed electronic to this registered design as required by Section 20(1)
To the meets Standa registra CRN:_ Registe Expiry Signate	best of my knowledge and belief, the appli- the requirements of the Safety Codes Act a and B51, Part 1, Clause 4.2, and is accepted ation in Category ered Date: Date: Ure:	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By: IAN WANG, P. Er This stamp and signature have been affixed electronic to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.
To the meets Standa registra CRN:_ Registe Expiry Signatu	best of my knowledge and belief, the appli- the requirements of the Safety Codes Act a rd B51, Part 1, Clause 4.2, and is accepted ation in Category ered Date: Date: Ure:	cation and CS d for	A 2021-02831 ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By: IAN WANG, P. Er This stamp and signature have been affixed electronic to this registered design as required by Section 20(1) the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.





Table 1** Scope of Fitting Designs

		s, Rev 1	
Reference	Catalogue (pages) or Drawing(s)	SOR-A-Serie	
	Design Code(s) of Construction	ASME B31.3-2018	
	Pressure Class(es) / Schedule(s)		
ressure	At Maximum Temperature	PE SUMMARY eries, Rev.a	
Rated P	At Ambient Temperature	SOR-A-Sor	
	MDMT	Per Code Mat'l	
Port	Connections and Size Range	UMMARY es, Rev. ¹	
	Material of Construction	SEE SCOPE S SOR-A-Serie	
Primary	Pressure Bearing / Retaining Component	FITTING	
	Item #	1	

Table 2 Additional Scope Information

(
etc.	
Illustrations,	
Options,	
Configurations,	
(Product	
References	
Detail and	
Additional	
List/Attach	

Example:

Series X Options

** For additional alternatives of Table 1, refer to Form AB-41a, Guide for Completing Form AB-41

Ashcroft A-Series Pressure Switch - Scope of Registration SOR-A-Series, Rev1

ASHCROFTinc

Pressure Switch Type	Drawing	Model	Process Connections	Maximum Allowable Working Pressure	Maximum Temperature (°F) [1]	Wetted Materials Code of Construction
		BV-1	1/4" NPT M/F 1/8" NPT M/F 7/16-20 SAE VCR, VCO	200	-18.4 to 212	
Watertight &	50C411 &	S-2	3/4" Sanitary Blank Socket	200		Type 316L, A240/A358, UNS 31603 ASME B31.3 2020)
	50C412	BV-3	1/4" NPT Male 1/8" NPT Male	7500	-40 to 212	
		BV-2	7/16-20 SAE Blank Socket	2000		ABSA SAFETY CODES ACT - PROVINCE OF ALBERTA
notes: 1 Signed: Dated:	Refer to Ash	2021	-PS-Rev 1 for calcu	lations.	-	ACCEPTED: 0F14836.52 See acceptance letter for conditions of registration. Date: 2021-06-23 By: IAN WANG, P. Eng

This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.



PRESSURE REGISTRATION PACKAGE

PRP03-AC-PS, Rev. 2

Component Registration Support

Manufacturer:	Ashcroft Inc. 250 East Main Street Stratford, CT 06614-5145, USA
Product Category:	CSA B51-2019, Fitting
Products:	A-Series Pressure Switches Watertight BV-1, BV-2, BV-3, S-2, Explosion Proof H-2, H-3, H-4, H-5, S-2, S-3
CODES OF CONSTRUCTION:	ASME B31.3 – 202-



TABLE OF CONTENTS

SECTION 1	-	Revision Record
SECTION 2	-	Executive Summary of Results
SECTION 3	-	Design Calculations
SECTION 4	-	Witnessed Burst-Test Calculations
SECTION 5	-	Conclusion
APPENDIX A	-	Witnessed Burst Test Results



SECTION 1

REVISION RECORD



REVISION RECORD

Revision	Date	Description	Manufacturer/Date
0	24/05/2011	New	Ashcroft Inc
1	12/08/2011	Tests Added	
2	06/19/2021	ABSA	- and P
		request	
			Date: June 23, 2021

By signing above, Ashcroft Inc. acknowledges that the signatory is an authorized person of Ashcroft Inc. responsible for the compliance of the product to the requirements set out herein. Furthermore, the signatory confirms that he/she has read, understood, checked and agreed with the contents of this report and the associated requirements of the referenced code(s) of construction.



SECTION 2

Executive Summary of Results

Page 5 of 34 (attachments)



2 <u>EXECUTIVE SUMMARY OF RESULTS</u>

2.1 Summary of Analytical Approach

With the A-series pressure switch process connection threaded to the pressurized process piping, Ashcroft pressure switches are subjected to the process piping internal pressure. A photograph of typical units is shown in **Figure 1**.



Figure 1 Typical Ashcroft A-series Pressure Switch (Watertight shown)

Ashcroft A-Series pressure switches in the scope of this registration are for the watertight (general purpose) version (drawing 50C411, Rev. A) and hazardous locations version (drawing 50C412, Rev. 3) whose pressure boundary parts are identical to each other, and therefore the distinction between hazardous locations and watertight (general purpose) versions is not relevant to the analysis here, and is therefore provided for information only.

The common pressure boundary parts under the scope of this registration are described in drawing 50C411, Rev. A and drawing 50C412, Rev. 3. Four unique pressure boundary assemblies represent all possible pressure bearing ranges, and are described below by the four diagrams in **Figure 2**, **Figure 3**, **Figure 4**, and **Figure 5**.



















Figure 5 Typical A-Series Pressure Switch BV-2 30-200 psi.



With referenced to **Figures 2, 3, 4 & 5 above** the Ashcroft pressure switches considered herein share common pressure boundary components as follows:

A. <u>Metallic socket</u> connects to piping. The socket is a wetted part subject to internal pressure and is shown in **section 3.4** of this report to comply with ASME B31.3 paragraph 304.1.1 for internal pressure of the thinnest wall. Threaded sockets are also reviewed in **section 3.3** of this report per ASME B31.3 para. 314.1.2(a):

The socket is available in the following versions described in drawing 141B445:

- Threaded per **section 3.3** of this report, reviewed per ASME B31.3 para. 314.1.2(a):
 - 1/8" male NPT, 1/4" male NPT, 1/8" female NPT, 1/4" female NPT, 7/16-20 SAE.
- Blank Socket section 3.4 per ASME B31.3, paragraph 304.1.1.
- Sanitary Seals Socket **section 3.4** per ASME B31.3, paragraph 304.1.1.
- Weld-able socket **section 3.4** per ASME B31.3, paragraph 304.1.1.
- B. <u>Metallic housing</u> is not wetted, and is therefore not subjected to direct internal process pressure. The internal wall of the metallic housing acts to prevent the piston stroke from exceeding its limit, and is subject to a force from the piston. This is examined in **section 3.4** of this report. The internal thread withstands a force, and is calculated in **section 3.5** per ASME B1.1 for information. If the piston stroke is exceeded, the diaphragm seal will be compromised. The interaction fo the diaphragm, piston and housing is essential as a means of ensuring pressure is retained by the switch. Therefore in **section 4** the material used in the construction of the metallic housing, namely UNS S31603, A 240/A A276, 316L, is the control material for the ASME Section VIII, Div. 1, UG-101 (m) burst testing, per ASME B31.3, paragraph 304.7.2(c).
- C. <u>Diaphragm</u> acting as a seal which is backed by the metallic piston, which is in -turn backed by the housing. In **section 4** of this report the weakest diaphragm is Buna which is qualified by witnessed burst testing per ASME Section VIII, Div. 1, UG-101(m) per ASME B31.3 paragraph 304.7.2 (c) to test its ability to seal against the metallic piston and metallic housing.
- D. <u>Metallic piston</u> actuates switches, but is stopped by the internal wall of the metallic housing, and not subject to direct process pressure but is subject to a shear force from the process pressure. The piston shear is calculated herein for information.



E. Lower piston assembly exists only in the BV-2 and BV-3 types, and serve to distribute pressure evenly against the diaphragm. These parts cannot be computed with a reasonable assurance of accuracy and are therefore subject to burst testing in **section 4** of this report per ASME B31.3 paragraph 304.7.2, ASME Boiler and Pressure Vessel Code, Section VIII, Div.1, UG-101(m).

Material properties are derived from ASME B31.3 - 2010 with respect to calculation of internal pressure retaining capacity of a pipe for more rigorous design.

2.2 Contents of report

The following is a brief description of the contents of this report.

Section 3	Design Calculations:
	 NPT Threadability per ASME B1.20.1 and B36.19. MAWPs determination per ASME B31.3 para 104. Piston head shear. Housing and VCR/VCO fitting thread shear.
Section 4	Witnessed Burst-Test Calculations
	 Section VIII, Div. 1, UG-101 witnessed burst-test calculations.
Section 5	Conclusions and Summary
Appendix A	ASME BPVC Section VIII, Div. 1, UG-101 witnessed burst test results.



2.3 Scope of Registration

The following shows the products included in this design registration.

Table 1 Ashcroft Pressure Switch Scope of Registration

						Materials								
Pressure Switch Type	Drawing	<mark>Model</mark>	Process Connection Sizes (in)	Pressure @ ambient (psi)	<mark>Upper</mark> Piston	Lower Piston	Piston Seal	<mark>Diaphragm</mark>	<mark>Sleeve</mark>	<mark>Backup</mark> Ring	Code of Construction			
		<mark>BV-1</mark>		<mark>200</mark>	<mark>212 [1]</mark>	<mark>316L</mark>		<mark>Buna, Viton</mark>	<mark></mark>					
Matortight	50C411	BV-2	1/4 NPT, 1/8 NPT, 7/16-20 UNF 2A, Sanitary	<mark>2000</mark>	212 [1]	<mark>Brass</mark>	<mark>316L</mark>	<mark>Buna, Viton</mark>	<mark></mark>		Teflon	ASME B31.3 - 2020		
watertight	<mark>50C411</mark>	<mark>BV-3</mark>		<mark>7,500</mark>	212 [1]	<mark>Brass</mark>	<mark>316L</mark>	<mark>Buna, Viton</mark>	<mark></mark>	<mark>316L</mark>	Teflon			
		<mark>S-2</mark>		<mark>200</mark>	<mark>212</mark>	<mark>Brass</mark>		<mark></mark>	<mark>316L</mark>		<mark>Silicone</mark>			
		H-2		<mark>100</mark>	<mark>185</mark>	<mark>316L</mark>		<mark>Buna</mark>	<mark></mark>					
		H-3		<mark>400</mark>	<mark>185</mark>	<mark>316L</mark>		<mark>Buna</mark>	<mark></mark>					
Explosion	E0C412	<mark>H-4</mark>		<mark>1000</mark>	<mark>185</mark>	<mark>Aluminum</mark>	<mark>316L</mark>	<mark>Buna</mark>	<mark></mark>		Teflon			
<mark>proof</mark>	<mark>50C412</mark>	H-5		<mark>7,500</mark>	<mark>185</mark>	<mark>Aluminum</mark>	<mark>316L</mark>	<mark>Buna</mark>	<mark></mark>	<mark>316L</mark>	Teflon			
		<mark>S-2</mark>		<mark>100</mark>	<mark>185</mark>	Aluminum			<mark>316L</mark>					
		<mark>S-3</mark>		<mark>400</mark>	<mark>185</mark>	<mark>Aluminum</mark>			<mark>316L</mark>					

[1] 185°F for Buna seal.



SECTION 3 DESIGN CALCULATIONS



3.1 Design Conditions

The design temperature is governed by the component with the lowest allowable design temperature. The following design data is of the pressure switch configuration and is tabulated from several references:

Table 2 Material Specifications and Design Temperatures

Part	Material	Temperature Range
Piston	ASTM A479 UNS S31603 (S.S. 316L) ASTM B16 UNS C36000 (Brass) <mark>(Aluminum)</mark>	-20°F to +212°F
Diaphragm	ASTM A240 UNS S31603 (S.S. 316L)	-20°F to +212°F
Sleeve	ASTM A479 UNS S31603 (S.S. 316L)	-20°F to +212°F

Assumptions:

a. The user is cautioned that if conditions exist which may result in corrosion or erosion of pressure boundary materials, fatigue, shock, chemical incompatibility, and/or low temperature impact, a suitable de-rating shall be applied to the Maximum Allowable Working Pressure (MAWP) of these components which shall be advised by the factory and are outside of the scope of the analysis herein. The analysis herein is for non-nuclear service. Lethal service per ASME Boiler and Pressure Vessel Code is not considered.

b. Provisions of ASME B31.3 – 2020 and its referenced codes of construction relating to, and not limited to post production hydrostatic testing, heat treatment, non-destructive testing, welding qualifications and procedures are the responsibility of the manufacturer and shall be followed by the manufacturer. Updates to the ASME B31.3 and its referenced codes of construction are to be monitored by the manufacturer as changes pertain to this registration and the registration updated accordingly by the manufacturer.

c. Production units associated with this report through a Canadian registration number shall be of duplicate of similar parts and comply with ASME B31.3 and its referenced codes of construction.



3.2 Weld Analysis

Housings are welded to sockets per drawing 50C411 sheet 2 of 4, and the BV-3 stop portion of the lower piston assembly is laser beam welded (LBW, see Drawing 84A518). As the welded assembly strength cannot be computed with ar reasonable assurance of accuracy, they are tested in **section 4** of this report per ASME B31.3 – paragraph 304.7.2 (c), Section VIII, Div. 1, UG-101(m).

3.3 **Process Connection Thread Mounting**

3.3.1 General

Threaded joints shall not be used where severe corrosion, crevice corrosion, shock or vibration is expected to occur.

Wall thickness less than that of standard weight of ASME B36.10/B36.19 stainless steel pipe shall not be threaded, regardless of service. Pipe schedules below 40S (Standard) shall not be threaded. This is in accordance with threading requirements per ASME B31.3 para. 314.1.2(a) and ASME B1.20.1 for NPT process connections.

3.3.2 Analysis

The following example calculation provides assurance of the sufficiency of the pipe wall thickness for threading. The example is for standard size 1/4" NPT, Drawing 141B445 Sheet 1 of 5.

NPS	=	Nominal Pipe Size of conn 0.25	ection (1/4–18 NPT)
O.D.	= =	Minimum outer diameter 0.54"	(Drawing 141B445 Sheet 1 of 5)
I.D.	=	Maximum inner diameter 0.228"	(Ibid.)
Thick.	= = =	Minimum wall thickness (O.D. – I.D.) / 2 0.156"	
Т	= = =	Nominal Min. Wall thicknes Thick. – 12.5% 0.137"	ss (ASME B16.11 para. 2.1.1)



t = Required Minimum Wall Thickness per ASME B36.19/B36.10 Schedule 40 (STD) for the given NPS. = 0.088"

Case Validation:

Т	>	t	?	
0.137	>	0.088	?	Yes. Therefore OK.

Table 3 below shows the thread mounting calculations for all seal connections included in the scope of this design registration.

<u>Table 3 Process Connection Thread Mounting per ASME B31.3 para.</u> <u>314.1.2(a)</u>

A-Series Switch Process Connection	Drawing	Equivalent NPS (in)	O.D. (in)	I.D. (in)	Thick. (in)	T (in)	B36.19/10 Sched. 40(STD) t (in)	Pass?
1/4 MNPT	141B445 1of5	0.25	0.540	0.228	0.156	0.137	0.088	YES
1/8 MNPT	141B445 2of5	0.125	0.405	0.228	0.089	0.077	0.068	YES
1/4 FNPT	141B445 3of5	0.25	0.840	0.340	0.250	0.219	0.088	YES
1/8 FNPT	141B445 4of5	0.125	0.840	0.228	0.306	0.268	0.068	YES
7/16-20 SAE	141B445 2of5	0.5	0.4375	0.228	0.105	0.092	0.068	YES

Therefore, by inspection, all the seals listed in Table 3 are constructed of process connections that are acceptable for threading per ASME B31.3 para. 314.1.2(a) and ASME B1.20.1 by falling under pipe schedule greater than 40 (STD).



3.4 Minimum Wall thickness requirements: Socket

The housing wall is behind the diaphragm, and is therefore not subject to process pressure. Therefore the following analysis was performed to confirm that the socket, drawing 141B455 is wall is thick enough to meet the requirements of ASME B31.3 under paragraph 304.1.1 for internal pressure of the thinnest wall.

Socket, drawing 141B455 (common thinnest wall for all thread sizes and types):

Ρ	=	7,500 psi		{Table 2.3 above}			
S	= =	Basic Allowa 16,700 psi	able Stress {ASME B31.3 Table A-1, note 37, A276 refers to A240 316L, design temperature 212°F}				
E	= =	Quality Facto 1	Quality Factor 1 {ASME B31.3 Table A-1B, A182}				
W	=	Weld Joint Strength Reduction Factor 1.0 {ASME B31.3 para. 302.3.5(e), Temperature < 950°F					
С	= =	Sum of Mech 0.02	anical Allowances {minimum}				
Т	= = =	Min. wall thic (D – d) / 2 0.193"	kness				
D	= = =	Min. Outer D 0.830 – 0.00 0.823"	iameter 7(tolerance)	{Drawing 141B455}			
d	= = =	Max. Inner Diameter 0.430 + 0.007 (tolerance) 0.437"		{lbid.}			
Y	= = =	Temperature (d+2c) / (D+d 0.4	Coefficient I+2c) <i>for T<d <="" i="">6</d></i>	{ASME B31.3 Table 304.1.1}			
t1	= = =	Minimum Re(P*D / [2 (S*E 0.1587"	quired Wall Thicknes *W + P*Y)] {ASMI	es according to equation (3a) E B31.3 para. 304.1.2(a) Eq. (3a)}			



t 2	= = =	Minimum Required Wall Thickness accord $P(d + c) / \{2 [SEW - P(1 - Y)]\}$ 0.1497"	rding to equation (3b) <i>{Ibid.</i> Eq. (3b)}
t _m	= = =	Minimum Required Wall Thickness MAX (t ₁ , t ₂) + c 0.1787"	{ <i>lbid.</i> para. 304.1.1 Eq. (2)}

Case Validation:

 T
 >
 tm

 0.193"
 >
 0.1787"
 YES. Therefore OK.

Therefore, the thinnest pipe is designed for the rated pressure per ASME B31.3 - 2010.

3.4 Piston Head Shear

Upper piston head shear strength against the housing walls may be calculated with reasonable assurance of accuracy.

With reference to **Figure 3** below, the upper piston head, drawing 344184 experiences a shear force due to internal pressure acting on the base as it stops against the housing wall, drawing 476B217. By inspection the housing wall is thicker than the piston. The shear force at the sidewalls of the piston head where it meets the housing is therefore calculated. The internal pressure is assumed to act entirely at the piston head diameter, and the piston head walls in contact with the housing are assumed to resist the resulting shear force entirely.





The calculation below is for worst case 7500 psi rating brass upper piston, Drawing 344A184 Sheet 2 of 2. **Table 4** then shows tabular calculations for all pistons included in this registration.

Ρ	= = =	maximum rated pres 7500 + 25% 9,375 psi	ssure + 25%
D	= =	maximum piston hea 0.621"	ad diameter {Drawing 344A184 Sheet 2 of 2}
F	= = =	safe shear force due $P * \pi D^2/4$ 2,840 lbf	e to internal pressure
Dc	= = =	minimum contact dia 0.621 – 0.002 0.619"	ameter at piston head { <i>Ibid.</i> }
L _c	= = =	minimum contact ler 0.134 – 0.007 0.127"	ngth at piston head { <i>Ibid.</i> }
Ac	= = =	$\begin{array}{l} \mbox{Minimum contact su} \\ \pi^* D_c^* L_c \\ 0.247 \ \mbox{in}^2 \end{array}$	rface area under shear
Ss	= = =	Maximum shear stre F / A _c 11,497 psi	ess at piston head
Y	= =	maximum allowable 20,000	material yield stress at design temperature {ASME B31.1 Case 175, Table 1, B16 C36000}
S _{s,allow}	= = =	maximum allowable 0.6 * Y 12,000 psi	material shear stress {acceptable practice}
Case	Validat	ion:	

S_{s,allow} > S_s 12,000 > 11,497 **YES. Therefore OK.**

Table 4 below shows tabular calculations for shear of all pistons included in this registration.



Piston Drawing	P (psi)	D (in)	F (lbf)	D _c (in)	L _c (in)	A _c (in²)	S₅ (psi)	Y [1] (psi)	S _{s,allow} (psi)	Pass?
344A184 Sheet 1 of 2	500	0.617	149	0.612	0.097	0.1865	802	20,000	12,000	YES
344A184 Sheet 2 of 2	9375	0.621	2840	0.619	0.127	0.247	11,497	20,000	12,000	YES
344A185	9375	0.227	379	0.109	0.2 [2]	0.0685	5,540	25,000	15,000	YES
344A186	9375	0.11	89	0.108	0.2 [2]	0.0679	1,313	25,000	15,000	YES

Notes

[1] Y=20ksi for B16 C36000 brass from ASME B31.1, Case 175, Table 1, <1". Y=25ksi for A276/182 S31603 S.S. from ASME B31.3 Table A-1.

[2] Conservative underestimates.

Therefore, by inspection, piston head shear strength is satisfactory for all piston configurations and for worst case pressure, dimensional, and material conditions.



3.5 Housing Thread Shear

Housing thread shear strength against the force due to internal pressure may be calculated with reasonable assurance of accuracy per ASME B1.1 Appendix B.

With reference to **Figure 4** below, the housing experiences a force due to internal pressure acting at the diameter of the threads. This results in a shear force at the threads of the housing. The internal pressure is assumed to act entirely at the thread major diameter, and the engaged threads are assumed to resist the resulting shear force entirely.



Figure 4 Housing Thread Shear Analysis (Drawing 476B217)

The following example calculation is for shear of the external thread, 7/8-32 UN 2A at worst case 7500 psi, followed by shear of the internal thread, 5/8-32 UN 2B.

Ρ max. rated pressure + 25% = 7500 + 25% = = 9,375 psi D thread major diameter = = 0.625" {7/8-32 UN 2A} А cross section area = = $PI^{D^{2}/4}$ 0.307 in² = F max. shear force on threads = = P*A 2876 lbf = max. minor diameter of internal thread $D_{1max} =$ 0.8490" {ASME B1.1, 7/8-32 UN 2A} =



d _{2min}	=	min. pitch diameter of exte 0.8499"	rnal thread <i>{Ibid.</i> }			
n	=	number of threads per inch 32	\ {Ibid.}			
LE	=	min. thread engagement length 0.490" {Drawing 476B217}				
ASs	= = =	external thread shear area per B1.1 Appendix B PI * n * LE * D_{1max} * [1/2n + 0.57735*($d_{2min} - D_{1max}$)] 0.6752 in ²				
Ss	= = =	max. thread shear stress F/AS _s 4,260 psi				
For the	e interr	al thread:				
F	=	2876 lbf	{as above}			
d _{min}	=	min. major diameter of exte 0.6179"	ernal thread {ASME B1.1, 5/8-32 UN 2B}			
D _{2max}	=	max. pitch diameter of inte 0.6093"	rnal thread { <i>Ibid.</i> }			
n	=	32	{as above}			
LE	=	0.520"	{Drawing 476B217}			
ASn	= = =	internal thread shear area per B1.1 Appendix B PI * n * LE * d _{min} * [1/2n + 0.57735*(d _{min} – D _{2max})] 0.6651 in ²				
Ss	= = =	max. thread shear stress F/AS _n 4,325 psi				
Y	=	material min. yield stress 25,000 psi {ASME	E B31.3 Table A-1, A2776/182 316L}			
S _{s,allow}	= = =	max. allowable shear stres 0.6*Y 15,000 psi	s {acceptable practice}			



Case Validaton:			
Ss	<	S _{s,allow}	?
4260 or 4235	<	15000	YES. Therefore OK.

In addition, the tabulation below shows that thread shear is also acceptable for the VCR/VCO fittings included, drawings 141A341 & 141A342. Nomenclature is per the example above.

Drawing	Hous Thre (EXTER	sing ead RNAL)	P (psi)	D (in)	A (in²)	F (lbf)	D _{1max} (in)	d _{2min} (in)	n	LE (in)	AS₅ (in²)	S₅ (psi)
141A341/2	9/16-18	8 UNF	9,375	0.563	0.249	2330	0.5150	0.5182	18	0.200	0.1726	13,502
Weakest Material	Y (psi)	S _{s,allow} (psi)	S₅ <s₅< th=""><th>allow?</th><th></th><th></th><th></th><th></th><th></th><th></th><th></th><th></th></s₅<>	allow?								
A276 S31603	25,000	15,000) Y	ES								

Hence, the shear of housing and VCR/VCO fitting threads are acceptable per ASME B1.1 Appendix B.



3.5 Sanitary Clamp per ASME BPVC, Section VIII, Division 1, Mandatory Appendix 24.

Sanitary clamp, Drawing 48A263, is checked for compliance with ASME Section VII, Appendix 24 – Design Rules for Clamp Connections. **Figure 5** below is extracted from Drawing 560B490 and shows dimensions equivalent to those depicted in Appendix 24, Fig. 24-1(c). The calculation next is for worst case dimensions, and a 500 psi rated pressure was assumed applicable, i.e. no diaphragm was considered and the pressure was assumed to fully act internally on the clamp.



.Figure 5 ASME Section VIII, Appendix 24 Illustration

Given	Geom	etry	{Drawing 560B490}
A	= =	outside hub diamete 0.98"	er
В	= =	inside hub diameter 0.521"	{worst case}
N	= =	hub neck outside dia 0.5"	ameter
Ci	= =	clamp inside diamet 0.75"	er, assembled {assumed at gasket mean diameter}



- g_0 = hub neck thickness at small end = 0.3525"
- $g_1 =$ hub neck thickness at intersection with hub shoulder = g_0 {Appendix 24, Figure 24-1(c)}
 - = 0.3525"
- T = hub shoulder thickness = 0.224"
- Φ = clamp shoulder angle
 = 22.5 degrees
- μ = friction angle
 - = $\Phi 5$ {Appendix 24, para. 24-4(b)(4), results independent}
 - = 17.5 degrees

Calculated Geometry

- $g_2 =$ hub shoulder height = (A - N)/2= 0.115"
- C = diameter of effective clamp-hub reaction circle = (A + Ci)/2
 - = 0.865"
- N_g = gasket seating width used to determine b₀ below {ASME Section VIII, Appendix 2, Table 2-5.2(1a) notation 'N'} = 0.126" {worst case maximum}
- $b_0 = basic gasket seating width {$ *ibid.* $with notation 'b_o'}$ $= N_g/2$
 - = 0.063"
- b = effective gasket seating width {*ibid.* with notation 'b'}
 - $= b_0 \text{ for } b_0 <= 0.25; \quad 0.5 \sqrt{b_0} \text{ for } b_0 > 0.25$
 - = 0.063"

G	=	diameter at location of gasket load reaction		
	=	mean gasket contact face diameter for $b_0 \le 0.25$,		
		outside gasket contact face diameter less 2b for b ₀ > 0.25		
	=	0.75" {at C _i }		



Calculated Moments

Ρ	= =	maximum internal design pressure 500 psig {worst case maximum}
HD	= = =	hydrostatic end force on bore area 0.785 B ² P 106.5 lbf
h _D	= = =	radial distance from C to circle where H_D acts $[C - (B + g_1)]/2$ -0.0042"
MD	= = =	moment due to H_D H_D h_D -0.5 in-lbf
н	= = =	total hydrostatic end force 0.785 G ² P 253.7 lbf
ΗT	= = =	difference between hydrostatic end forces H - H _D 147.2 lbf
h⊤	= = =	radial distance from C to circle where H⊤ acts [C – (B + G)]/2 0.1013"
M⊤	= = =	moment due to Η _Τ Η _Τ h _Τ 14.9 in-lbf
M _F	= = =	offset moment $H_D(g_1 - g_0)/2$ 0 in-lbf
h ₂	= = =	average thickness of hub shoulder T – (g₂ tan Φ)/2 0.2002"
ħ	= =	axial distance from hub face to hub shoulder ring centroid $\frac{T^2g_1 + h_2^2g_2}{2 (Tg_1 + h_2g_2)}$
	=	0.1093"



М _Р	= = =	pressure moment 3.14 PBT (T/2 – ħ) 0.5 in-lbf			
m	= =	gasket factor {ASME BPVC Section VIII, Appendix 2, Table 2-5.1} 1 {>=75A Shore durometer}			
Hp	= = =	total joint contact surface compression load 2 b*3.14 GmP 159 lbf			
W _{m1}	= = =	minimum required total bolt load for operating condition 0.637 (H + H _p) tan($\Phi - \mu$) 23 lbf			
У	= =	gasket seating stress{BPVC Section VIII, App. 2, Table 2-5.1}200 psi{>=75A Shore durometer}			
H _m	= = =	total axial seating requirements for makeup 3.14 bGy 31.8 lbf			
W _{m2}	= = =	minimum required total bolt load for gasket seating 0.637 H _m tan(Φ + μ) 17 lbf			
W _{m3}	= = =	minimum required total bolt load for assembly $0.637(H + H_p)$ tan($\Phi + \mu$) 220.6 lbf			
Wo	= = =	total design bolt load for operating condition W _{m1} {Appendix 24, para. 24-4(d) Equation (4)} 23 lbf			
Sa	= =	maximum allowable design stress of bolt material at room Temp. 25000 psi {assumed value, results independent}			
Sb	= =	maximum allowable design stress of bolt material at design Temp. 25000 psi {assumed value, results independent}			
A _{m1}	=	total cross-section area of bolts per clamp lug at thread root or section of least diameter under stress, required for operating condition $W_{m1}/2S_b$			



= 0.00046 in²

A _{m2}	=	total cross-section area of bolts per clamp lug at thread root or section of least diameter under stress, required for gasket seating					
	=	W _{m2} / 2S _a					
	=	0.00034 in ²					
A _{m3}	=	total cross-section area of bolts per clamp lug at thread root or section of least diameter under stress, required for assembly					
	=	W _{m3} / 2S _a					
	=	0.00441 in ²					
A _{mL}	=	total cross-section area of bolts per clamp lug					
	=	0.00441 in^2					
A _{bL} =		total cross-section area of bolts per clamp lug using the smaller of					
	_	the root diameter of thread or least diameter of unthreaded portion					
	=	0.00441 in ² {assumed value, results independent}					
Wa	=	total design bolt load for assembly condition					
	=	$(A_{mL} + A_{bL}) S_a$ {Appendix 24, para. 24-4(d) Equation (5)}					
	=	220.6 lbf {equal to W_{m3} }					
H_{Go}	=	difference between total effective axial clamping preload and sum of H and H_p , operating					
	=	1.571 W _o /tan(Φ + μ) – (H + H _p)					
	=	- 369.7 lbf					
H_{Ga}	=	difference between total effective axial clamping preload and sum of H and H _p , assembly $1.571 W_{o}/tan(\Phi + \mu) = (H + H_{o})$					
	=						
	=	0.3 lbf					
h _{G₀}	=	radial distance from C to where H_{Go} acts					
	=	0 {full face contact geometry}					
h _{Ga}	=	radial distance from C to where H _{Ga} acts					
	=	0 {full face contact geometry}					
M _{Go}	=	moment due to H _{Go}					
	=						
	=	U IN-IDI					



M _{Ga}	= = =	moment due to H _{Ga} H _{Ga} h _{Ga} 0 in-Ibf
M _{Ro}	= = =	radial clamp equilibriating moment, operating 1.571 W₀ {ħ – T + [(C – N)tanΦ]/2 - 3.3 in-lbf
M _{Ra}	= = =	radial clamp equilibriating moment, assembly 1.571 W _a {ħ – T + [(C – N)tanΦ]/2 - 31.5 in-lbf
Moo	= = =	total rotational moment on hub, operating 0.785 $W_o(C-G)$ / tan(Φ + $\mu)$ $\$ {App 24, para. 24-5(d) Equation (6)} 1.3 in-lbf
M _{Oa}	= = =	total rotational moment on hub, assembly 0.785 $W_a(C - G)$ / tan($\Phi + \mu$) (<i>Ibid.</i>) 12.6 in-lbf
I _h	= = =	moment of inertia of hub relative to its neutral axis $g_1T^3/3 + g_2h_2^3/3 - (g_2h_2 + g_1T)\hbar^2$ 0.000410 in ⁴
ğ	= = =	radial distance from B to hub shoulder ring centroid $\frac{Tg_1^2 + h_2g_2(2g_1 + g_2)}{2 (Tg_1 + h_2g_2)}$ 0.22902"
М _{Но}	= = =	reaction moment at hub neck, operating $M_{Oo}/\{1$ + [1.818/ $\!\sqrt{(Bg_1)}$ [$T-\hbar$ + 3.305*I_h/(g_1^2(B/2 + ğ))] $\}$ 0.8 in-lbf
М _{На}	= = =	reaction moment at hub neck, assembly $M_{Oa}/\{1+[1.818/\sqrt(Bg_1)][T-\hbar+3.305^*I_h/(g_1^2(B/2+\check{g}))]\}$ 8 in-lbf
Calcu	lated H	Hub Stresses (Appendix 24, para. 24-6 & 24-7)
f	= =	hub stress correction factor 1.0 {BPVC Section VIII, Appendix 2, Figure 2-7.6, $g_1/g_0=1$ }
S ₁₀	= = =	hub longitudinal stress, operating f { PB²/[4g₁(B + g₁)] + 1.91M _{Ho} /[g₁²(B + g₁)] } 124.8 psi



S _{1a}	= = =	hub longitudinal stress, assembly f { PB²/[4g₁(B + g₁)] + 1.91M _{Ha} /[g₁²(B + g₁)] } 250.3 psi
S ₂	= = =	hub hoop stress P (N² + B²)/(N² – B²) 1432.6 psi
Zo	= = =	clamp-hub taper angle, operating Φ – μ 5 degrees
Zg	= = =	clamp-hub taper angle, gasket seating and preload Φ + μ 40 degrees
S ₃₀	= = =	hub axial shear stress, operating 0.75 W₀ / [T (B + 2g₁) tan Z₀] 718.1 psi
S _{3a}	= = =	hub axial shear stress, assembly 0.75 W _a / [T (B + 2g ₁) tan Z _g] 718.1 psi {this would increase for a larger assumed value of A_{bL} , however order of magnitude variations do not affect the validation below}
Qo	= = =	reaction shear force at hub neck, operating 1.818M _{Ho} / $\sqrt(Bg_1)$ 3.5 lbf
Qa	= = =	reaction shear force at hub neck, assembly 1.818M _{Ha} / $\sqrt(Bg_1)$ 33.8 lbf
S 40	= = =	hub radial shear stress, operating 0.477Q _o / [g ₁ (B + g ₁)] 5.5 psi
S _{4a}	= = =	hub radial shear stress, assembly 0.477Q _a / [g ₁ (B + g ₁)] 52.3 psi { <i>Ibid.</i> }
S ₉₀	=	bearing stress at clamp-to-hub contact, operating W_o / [(A – C _i)C tanZ _o]



= 1321.6 psi

S _{9a}	= = =	bearing stress at clamp-to-hub contact, assembly W _a / [(A – C _i)C tanZ _g] 1321.6 psi { <i>Ibid.</i> }			
<u>Allowa</u>	ble De	esign Stress	ses (Appendix 24, para. 24-8 Table 24-8)		
Soн	=	allowable 16700 psi	design stress of hub material, operating {ASME BPVC Section II Part D, A182 316L at 212°F}		
Sah	=	allowable 16700 psi	design stress of hub material, assembly { <i>Ibid.</i> at ambient}		
$S_{10, allo}$	w	= mai = 1.5	ximum allowable value of S _{1o} Sон		
$S_{1a, allo}$	w	= 250 = mai = 1.5 = 250	кimum allowable value of S _{1a} S _{AH} 950 psi		
S _{2, allow}	I	= ma: = S _{O⊦} = 167	ximum allowable value of S ₂ , '00 psi		
S _{30, allo}	w	= mai = 0.8 = 133	ximum allowable value of S ₃₀ S _{OH} i60 psi		
S _{3a, allo}	w	= mai = 0.8 = 133	ximum allowable value of S _{3a} S _{AH} 60 psi		
S4o, allo	w	= ma: = 0.8 = 133	ximum allowable value of S₄₀ S _{OH} 860 psi		
S _{4a, allo}	w	= mai = 0.8 = 133	ximum allowable value of S _{4a} S _{AH} 660 psi		
S _{90, allo}	w	= ma: = 1.6 = 267	ximum allowable value of S ₉₀ S _{OH} 20 psi		
S _{9a, allo}	w	= mai = 1.6 = 267	ximum allowable value of S _{9a} S _{AH} '20 psi		



Case Validation:

S ₁₀	<	S ₁₀ , allow	
124.8	<	25050	YES
S _{1a}	<	$S_{1a, allow}$	
250.3	<	25050	YES
S ₂	<	S _{2, allow}	
1433	<	16700	YES
0		0	
S ₃₀	<	S ₃₀ , allow	VEO
/18	<	13360	YES
S _{3a}	<	S _{3a, allow}	
718	<	13360	YES
S ₄₀	<	S _{40, allow}	
5.5	<	13360	YES
S _{4a}	<	S _{4a, allow}	
52.3	<	13360	YES
S ₉₀	<	S _{90, allow}	
1322	<	26720	YES
S _{9a}	<	S _{9a. allow}	
1322	<	26720	YES

Therefore, the $\frac{3}{4}$ " clamp end is sufficient for the pressure indicated per Appendix 24 of ASME BPVC, Section VIII, Division 1.



Section 4 Witnessed Burst Test Calculations

Page 33 of 39 (attachments)



4 <u>Witnessed Burst Test Calculations</u>

4.1 Burst Test Overview

ASME B31.3 paragraph 304.7.2 permits burst testing of unlisted assemblies. With reference to the Ashcroft pressure switches, the primary focus of this ASME Section VIII, Div. 1, UG-101 (a)(2)(b) *tests based on bursting of the part* is to determine the burst pressure (and subsequent MAWP under para. UG-101) of the unlisted piston/housing/spring/back-up-ring assemblies, whose combined strength cannot be computed with a satisfactory assurance of accuracy.

Burst tests were witnessed by an ASME National Board Authorized Inspector, whose valid commission number is written on each witnessed burst test report.

The piston head has been demonstrated above to be designed to resist the operating force exerted on it by the internal pressure by calculation with reference to ASME materials used.

The mode of failure was noted during the witnessed burst test reports, and in all cases the A-Series pressure switch components did not fail. All burst tests were stopped due to seal loss at the thread due to the unusually high pressures.

Please see UG-101 witnessed burst-test results in Appendix A. The parts were hydrostatically tested in the presence of a National Board certified Authorized Inspector until burst per ASME BPVC Section VIII, UG-101(m), and the burst pressure and mode of failure duly noted.



4.2 Burst Test Analysis

The pressure switches included in this design registration were grouped together depending upon the mode of construction or operation of the unlisted assemblies. The following table, referencing drawings 50C411 & 50C412, details the groupings and hence the qualified parts for a given burst-test unit.

Table 4.2 Analytical Groupings of Pressure Switches

Pressure	Rated
Switches	Pressure (psi)
BV-2	2,000
BV-1	200
BV-3	7,500
S-2	200

4.3 Maximum Allowable Working Pressure Calculations

The following assumptions apply to the hydrostatic test calculations:

- 1) The material and geometry of the assembly burst-tested is representative of a regular production unit. The tested unit was assembled by a method performed the same as for regular production units, which are controlled via a recognized quality system.
- 2) The tested unit is representative of the weakest assembly of the representative configuration tested. Each tested unit is representative of a variant assembly or assemblies and is burst with thinnest wall and subject to maximum process pressure.

The maximum allowable working pressures for the unlisted assemblies are calculated as follows:

P = $(B/4)^*E^*(S_{\mu} / S_{\mu r})$ {ASME Section VIII, UG-101 (m)(2)(a)}

where:

P = Calculated MAWP at room temperature

- B = Burst test pressure
- E = Efficiency of weld joint
- S_{μ} = Specified minimum tensile strength at room temperature



$S_{\mu r}$ = Maximum actual tensile strength at room temperature from heat lot

MAWP at design temperature for each material in use was calculated as follows:

 $P_0 = P^* (S / S_2)$ {*Ibid.* UG-101 (k)}

where:

- P₀ = Maximum allowable working pressure at design temperature
- P = From above
- S = Maximum allowable stress value at design temperature
- S₂ = Maximum allowable stress value at test temperature

The following calculation shows that the parts tested are constructed to pressure ratings consistent with ASME BPVC Section VIII, UG–101. **Table 4.3** provides tabular calculations for all burst-tested units. Each test was done for worst case pressure and material conditions. The example below is for test number 1 per **Table 4.3** below.

Model tested: BV-1 Qualifying Switches: BV-1 per Drawings 50C411 & 50C412.

В	=	12000 psi	
E	=	0.7	
Sμ	=	70 ksi {ASME 31.3 ta	able A-1, Type 316L, A240/A358}
S _µ r	=	512 MPa = 74.2 ksi	Appendix A}
P	=	$(B/4)^*E^*(S_{\mu} / S_{\mu r})$ {ASME Secti	on VIII, UG-101 (m)(2)(a)}
	=	(12000/4) * 0.7 * 0.942	
	=	1978 psi	
Check	k at am	nbient:	
Datad	Drago		

Rate	d Pres	sure <	P	?
200	psi	<	1689 psi	Yes. Therefore o.k.
S	=	16700 psi	{ <i>lbid.</i> @ 21	2°F}
S2	=	16700 psi	{ASME 31.	3 table A-1, Type 316L, A240/A358}
P_0	= =	P * (S / S ₂) 1978 psi	{ UG-101 (I	<)}

Check at design temperature 212°F:



Rated Pressure<</th> P_0 ?200 psi<</td>1978 psiYes. Therefore o.k.

Therefore, by inspection, the representative burst-tested configurations, as well as configurations qualified by those tested, were designed in compliance to ASME B31.3 – 2010.

5. Conclusion

With reference to the foregoing calculations and burst test results, the pressure switches evaluated in this report have been demonstrated to be designed per the applicable sections of ASME B31.3-2010.

The Scope of registration is summarized in Table 2.3 of Section 2.3.



Table 4.3 Witnessed Burst Test Results

					_
	DP < MAWP?	Yes	Yes	Yes	Yes
MAWP @ 212 °F	(UG-101 (k))	1978	11541	13190	1978
	S_2	16700	16700	16700	16700
	S	16700	16700	16700	16700
MAWP (UG-101 (m)(2))	psi @ ambient	1978	11541	13190	1978
	S _u /S _{uavg}	0.94213	0.94213	0.94213	0.94213
	S _{uavg}	74.3	74.3	74.3	74.3
	Su	70	70	70	70
	Э	0.7	1	1	0.7
Burst Pressure	psi	12000	49000	56000	12000
Design Pressure (DP)	psi	200	2000	7500	200
	Ashcroft Part	BV-1	BV-2	BV-3	S-2
	Test No.	1	2	3	4



Appendix A ASME BPVC Section VIII, Div. 1, UG-101 Witnessed Burst-Test Results



Ashcroft Witnessed Burst Test Report No.

Product Part No.: BU-2 (FIELD ADJUSTABLE) Product description: PISTON ASSEMBLY FOR A-SERJES SWITCH 2000# PSI

Project Identification: Ashcroft A-Series Pressure Switch watertight and explosion proof

Fitting Description: See diagram

	Test Rig P	ress	ure Gauge		
Manufacturer:	Acus				
	· ISHCE	OFT			···-
Serial Number:	0777	ß:	0302	C!	0832
Gauge Range:	7500psi	B:	30000 05;	C.	8000 Psi
Calibration Date:	2/16/2011	B:	5/17/11	C;	8/8/11
Attach	calibration certif	icate t	o witnessed tes	st repo	ort

TEST TEMPERATURE:

TEST DATE:

TIME:

70.7 F 8/11/2011 10:23

Material Certification References:

Material Certification Suavo



Ashcroft Witnessed Burst Test Report No. Factory Set Field Adjustable





BV-2 PISTON ASSEMBLY

 Item Gty Part No
 Description

 12d
 1
 344A164-03
 UPPER PISTON

 15a
 1
 344A165-01
 LOWER PISTON



BV-2 500-2000 psi

16

14b

or 14d

Material

BRASS

316L

TEFLO

BUNA

VITON

Notes:

16

- 1. Factory Set and Field Adjustable units interchangeable for purpose of pressure seal test.
- 2. Seal materials of similar durometer are assumed equivalent, and are limited and limit design temperature. Note o-ring material tested.

SB.ECT O-RNO PASED ON "SEAL" CODE ONDERE: 185A105-95 O-RING (FOR "B" SEAL) 185A105-98 O-RING (FOR "V" SEAL)

Representative Test Sample Diagram to be threaded into test apparatus

1-1b

14d

Rated Design pressure of proprietary sensor seal assembly: 2000 psi Minimum required burst target value: 9000 psi. Do not stop test at 9000 psi. Test burst sample to failure, noting mode of failure.



		Burst T	est Recorded Result	S
	Column 1 Pressure (psig)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4 Comments
	1000	-3505	Initialization pressure	Initialization pressure
	1214	, 5	10:23	
	14201412	, 5		
AJ	1621	. 5		
	1815	. 5		
	2018	• 5		NO LEAKS, NO BURST
J	4500	, 5	10:29	No LEAR, No BURST
B	9000	. S		NO LEAK, NO BURST
(30000	. <i>S</i>		NO LEAK NO BURST
C.	49000	••••••••••••••••••••••••••••••••••••••		FAELURE @ OF TEFLON
				NO BURST, NO LEAK IN UNIT
l				



Column 2 Hold time (minutes)	Column 3 Clock time	Column 4 Comments
	······	
	Column 2 Hold time (minutes)	Column 2 Column 3 Hold time (minutes) Clock time

* "PASS" and "FAIL" are defined above.

At what pressure did the sample FAIL or the test discontinued?:

49000 PSI

GENERAL OBSERVATIONS / COMMENTS / MODE OF FAILURE:

	TEFLON	TAPE	FARLED	\bigcirc	THREAD	NOT	THE	ACTURE
PRODUCT	PRODUCT							

Therefore, the maximum pressure observed is confirmed to be

49000 psi and the test is accepted.



The undersigned have witnessed the burst test pass pressure above and verified that the above MAWP is permissible per the burst result recorded in this witnessed burst test report:

Test Performed by:	National Board Authorized Inspector:
Name: <u>MANCY LASELL</u> Signature: <u>Manay LaseL</u> Organization: Ashcroft Inc 250 East Main Street, Stratford, CT, 06614 Test Date: <u>S/11/11</u>	Authorized Name: <u>Deunis</u> Paulos Signature: <u>Celeleús</u> Paulos Organization: <u>HSBCT</u> NB Commission expiry: <u>MB# 12054A</u> 12/31/11 Date : <u>S/11/11</u>

A facsimile of the National Board Authorized Inspector Commission is to be provided along with the witnessed burst test report.



Ashcroft Witnessed Burst Test Report No.

Product Part No .: BV-1 (EIELO ADJUSTABLE) Product description: O-RING PESTON A-SERES SWITCH 200 #Psi

Project Identification: Ashcroft A-Series Pressure Switch watertight and explosion proof

Fitting Description: See diagram

Test Rig Pressure Gauge				
Manufacturer:				
Asi	ACRAET			
Serial Number:				
A: 0777	B. OZZS			
Gauge Range:				
A: 7500 PSI	R ` 30 000			
Calibration Date:	š			
A:2/16/11	<u>B: 3/21/11</u>			
Attach calibrati	on certificate to witnessed test report			

TEST TEMPERATURE:

TEST DATE:

TIME:

68.1	° F	
8/11/	11	

11:30AM

Material Certification References:

Material Certification Suava



Ashcroft Witnessed Burst Test Report No.



Notes:

- 1. Factory Set and Field Adjustable units interchangeable for purpose of pressure seal test.
- 2. Seal materials of similar durometer are assumed equivalent, and are limited and limit design temperature. Note o-ring material tested.

Representative Test Sample Diagram to be threaded into test apparatus

Rated Design pressure of proprietary sensor seal assembly: 200 psi Minimum required burst target value: 900 psi. <u>Do not stop test at 900 psi.</u> Test burst sample to failure, noting mode of failure.



Ashcroft Witnessed Burst Test Report No.

		Burst T	est Recorded Results	5
	Column 1 Pressure (psia)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4
1	- 120	- 5	Initialization pressure	Initialization pressure
	128		11:20 AM	5
A	148	.5		
	165	-5-		
	<u> </u>	. 5		
	210	7.		
Ĭ	461	.5		
L	979	.5		NO BORST
Q	12000			BURST
		·		

FTP-AS, Rev 4



Column 1 Pressure (psig)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4 Comments
		A	

* "PASS" and "FAIL" are defined above.

At what pressure did the sample FAIL or the test discontinued?:

12000 PSI

GENERAL OBSERVATIONS / COMMENTS / MODE OF FAILURE:

HOUSENF WELD SEPARATED

Therefore, the maximum pressure observed is confirmed to be

12000 PST and the test is accepted.



The undersigned have witnessed the burst test pass pressure above and verified that the above MAWP is permissible per the burst result recorded in this witnessed burst test report:

Test Performed by:	National Board Authorized Inspector:
Name: <u>NANCY LASELL</u>	Authorized Name: Delanis Poulos
Signature: <u>Namey Loso DD</u>	Signature: <u>Access</u>
Organization:	Organization:
Ashcroft Inc 250 East Main Street, Stratford, CT, 06614	NB Commission expiry: NS# 120541A pxp: 12[3]
Test Date: <u>8/11/11</u>	Date : <u>8/11/11</u>

A facsimile of the National Board Authorized Inspector Commission is to be provided along with the witnessed burst test report.



Ashcroft Witnessed Burst Test Report No.

Product Part No.: BV-3 (FIELD ADJUSTABLE) Product description: PISTON A-SERTES SWETCH 7500 psi

Project Identification: Ashcroft A-Series Pressure Switch watertight and explosion proof

Fitting Description: See diagram

Те	st Rig Pressure Gauge)
Manufacturer:		
As	HCROFT	
Serial Number:		
A:0777	B0302	C: 0837
Gauge Range:		01
A: 7500PSI	_B: 30.000FS	000 28 : 2 1
Calibration Date:		
A: 2/16/11	B: 5/17/1	C: 8/8/11
Attach calibra	ation certificate to witnessed	test report

TEST TEMPERATURE:

TEST DATE:

TIME:

<u>68.1°F</u>	
8/11/11	
11:15 AM	

Material Certification References:

Material Certification S_{µavg}



Ashcroft Witnessed Burst Test Report No.

Factory Set

BV-3 5000-7500 psi



BUNA VITON



Notes:

14b 1 14d 1

- 1. Factory Set and Field Adjustable units interchangeable for purpose of pressure seal test.
- 2. Seal materials of similar durometer are assumed equivalent, and are limited and limit design temperature. Note o-ring material tested.

Representative Test Sample Diagram to be threaded into test apparatus

Rated Design pressure of proprietary sensor seal assembly: 7500 psi Minimum required burst target value: 33,750 psi. Do not stop test at 33,750 psi. Test burst sample to failure, noting mode of failure.



Ashcroft Witnessed Burst Test Report No.

		Duist I	est Recorded Results	
	Column 1 Pressure (psia)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4
			Initialization	Initialization pressure
Γ	3750	2.6	pressure	initialization pressure
	4500	. 5	10:50 AM	
A	5272	.5		
	6091			
	6777	.5		
L	7559			
B	162.50	. 5	11:00 AM	NO BURST
Sr	35,000	.5	11:05AM	NO BURST
[NO BURST
			·····	
			**	

Burst Test Recorded Results



Column 1 Pressure (psig)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4 Comments
			MANNING

* "PASS" and "FAIL" are defined above.

At what pressure did the sample FAIL or the test discontinued?:

56000 PSI

GENERAL OBSERVATIONS / COMMENTS / MODE OF FAILURE:

NO FATLURE. PUMP COULD NOT GO HIGHER

Therefore, the maximum pressure observed is confirmed to be

56000 PST and the test is accepted.



The undersigned have witnessed the burst test pass pressure above and verified that the above MAWP is permissible per the burst result recorded in this witnessed burst test report:

Test Performed by:	National Board Authorized Inspector:
Name: NANCY LASELL	Authorized Name: Domais Paulos
Signature: Noncy Looll	Signature: <u>Cleeley Dowlos</u> Organization: <u>HSISCT</u>
Organization: Ashcroft Inc 250 East Main Street, Stratford, CT, 06614	NB Commission expiry: 103412054A exp:12/31/1
Test Date: 8/11/11	Date : 8/11/11

A facsimile of the National Board Authorized Inspector Commission is to be provided along with the witnessed burst test report.

ASHCROFTINC.

Document: FTP-AS, Revision 4

Ashcroft Witnessed Burst Test Report No.

Product Part No .: 5-2 (FACTORY SET) Product description: PISTON ASSEMBLY (DIAPHRAGEN) A - SERIES SWITCH 2001 200050

Project Identification: Ashcroft A-Series Pressure Switch watertight and explosion proof

Fitting Description: See diagram

Test Rig Press	ure Gauge
Manufacturer:	· · · · · · · · · · · · · · · · · · ·
Serial Number: A: 0 777	B: 0225
Gauge Range: A: 7500 PSi	B: 30000
Calibration Date: A: 2/16/11	0: 3/21/11
Attach calibration certificate	to witnessed test report

TEST TEMPERATURE:

TEST DATE:

TIME:

70.7°F	
8/11/11	
11:57	

Material Certification References:

Material Certification S_{µavg}

ASHCROFTINC.

Document: FTP-AS, Revision 4

Ashcroft Witnessed Burst Test Report No.



Notes:

- 1. Factory Set and Field Adjustable units interchangeable for purpose of pressure seal test.
- 2. Seal materials of similar durometer are assumed equivalent, and are limited and limit design temperature. Note o-ring material tested.

Representative Test Sample Diagram to be threaded into test apparatus

Rated Design pressure of proprietary sensor seal assembly: 200 psi Minimum required burst target value: 900 psi. <u>Do not stop test at 900 psi.</u> Test burst sample to failure, noting mode of failure.



Ashcroft Witnessed Burst Test Report No.

Column 1	Column 2	Column 3	Column 4
Pressure (psig)	Hold time (minutes)	Clock time	Comments
115	. 5	pressure	Initialization pressure
128		11:50AM	
145	3 5		
169	~5		
188	.5		
218	• 5		
460	2.		
933	- 5		No BURST
12000		12:17	BURST

Burst Test Recorded Results



Column 1 Pressure (psig)	Column 2 Hold time (minutes)	Column 3 Clock time	Column 4 Comments

* "PASS" and "FAIL" are defined above.

At what pressure did the sample FAIL or the test discontinued?:

12000 PSE

GENERAL OBSERVATIONS / COMMENTS / MODE OF FAILURE:

WELD AT HOUSING SEPARATED

Therefore, the maximum pressure observed is confirmed to be

12000 PST and the test is accepted.



The undersigned have witnessed the burst test pass pressure above and verified that the above MAWP is permissible per the burst result recorded in this witnessed burst test report:

Test Performed by:	National Board Authorized Inspector:
Name: <u>NANCY LASELL</u>	Authorized Name: Jennis Poulus
Signature: Namey Los oll	Signature: <u>Received on top</u>
Organization:	Organization: 1+515C1
Ashcroft Inc 250 East Main Street, Stratford, CT, 06614	NB Commission expiry: NG# 12054A exp: 12/31
Test Date: <u>8//////</u>	Date : <u>8/11/11</u>

A facsimile of the National Board Authorized Inspector Commission is to be provided along with the witnessed burst test report.



Current issue date:	
Expiry date:	
Certificate identity numb	er

27 February 2020 31 January 2021 10268598 Original approval(s): ISO 9001 - 11 January 1994

Certificate of Approval

This is to certify that the Management System of:

Ashcroft, Inc.

250 East Main Street, Stratford, CT, 06614, United States

has been approved by Lloyd's Register to the following standards:

ISO 9001:2015

Approval number(s): ISO 9001 - 0011501

The scope of this approval is applicable to:

Design and Manufacture of Pressure and Temperature Calibration and Measurement Equipment. Distribution of Pressure and Temperature Measurement Equipment Sourced Globally.

Ciffs & Muckelly

Cliff Muckleroy Area Operations Manager Americas Issued by: Lloyd's Register Quality Assurance, Inc. for and on behalf of: Lloyd's Register Quality Assurance Limited



Lloyd's Register Group Limited, its affiliates and subsidiaries, including Lloyd's Register Quality Assurance Limited (LRQA), and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract. Issued by: Lloyd's Register Quality Assurance, Inc., 1330 Enclave Parkway, Suite 200, Houston, Texas 77077, United States for and on behalf of: Lloyd's Register Quality Assurance Limited, 1 Trinity Park, Bickenhill Lane, Birmingham B37 7ES, United Kingdom



Phil Reed, 250 East Main Street, Stratford, CT, 06614, United States Lloyd's Register Quality Assurance Inc. 1330 Enclave Parkway Suite 200 Houston, Texas 77077 United States

T +1 866-971-5772 www.lr.org

3 December 2020

To whom it may concern

Re: Confirmation that the certificate validity has been extended for a period of up to six months from the expiry date.

I am writing regarding your request for the certificate renewal assessment to be postponed, based on IAF ID3: 2011 Management of Extraordinary Events or Circumstances Affecting ABs, CBs, and Certified Organizations).

Based on the information available from your organization's management system, we have determined that your management system certification validity can be extended for a maximum of six months.

However, as soon as the effects of Covid-19 have subsided, it will be necessary to undertake a certificate renewal assessment as soon as possible. If the recertification is successfully completed during the six-month extension period, an updated certificate will be issued.

The date of issuance of the new certificate will be the date of completion of our technical review, which will be conducted after the completion of the renewal assessment. The expiry date will be three years from the expiry date of the current certificate.

It should be noted that IAF ID3 requirements are that if the renewal assessment (including technical review) is not completed during the extension validity period of 6 months, the certificate will be suspended, and an assessment based on the initial assessment duration will be required to reinstate the certificate.

Organization name: Ashcroft, Inc. Address: 250 East Main Street, Stratford, CT, 06614, United States Client No.: UQA0100118 Assessment standard: ISO 9001:2015 Scope of approval: Design and Manufacture of Pressure and Temperature Calibration and Measurement Equipment. Distribution of Pressure and Temperature Measurement Equipment Sourced Globally. Certificate number: 10268598 Expiry date of current certificate: 31 January 2021 End of extension validity period: 31 July 2021

Yours sincerely,

Ciffs & Muckeling

Cliff Muckleroy Area Operations Manager Americas

Working together for a safer world