



The manufacturer
may use the mark:



Revision 4.0 September 30, 2026
Surveillance Audit Due
July 1, 2029



Certificate / Certificat Zertifikat / 合格証

ASH 1602007 C001

exida hereby confirms that the:

B, D & T - Series Pressure Switches

Ashcroft Inc.

Stratford, CT - USA

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Certified Models:

Only the Model numbers listed in Section 3 of the Assessment Report are included.

Safety Function:

The B, D & T - Series Switches will de-energize the associated circuit when the trip pressure is reached. The de-energized switch position is with the NC switch contact open on a high pressure trip, or the NO switch contact open on a low pressure trip.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Valerie Motte

Evaluating Assessor

[Signature]

Certifying Assessor

Systematic Capability: SC 3 (SIL 3 Capable)**Random Capability: Type A, Route 2_H Device**

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Systematic Capability :

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates, Single Switch, in FIT*

Description	Trip	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Vacuum & Compound	High	0	45	0	152
	Low	0	50	0	150
Pressure, Metal Diaphragm	High	0	45	0	111
	Low	0	46	0	113
Pressure, Elastomeric Diaphragm	High	0	45	0	127
	Low	0	58	0	117
Pressure, Piston O-Ring	High	0	45	0	185
	Low	0	89	0	144
Differential Pressure	High	0	84	0	160
	Low	0	52	0	197
Temperature	High	0	45	0	136
	Low	0	68	0	116

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: ASH 16/02-007 R002 V4 R0

Safety Manual: I&M900-10253, Rev A, March 2017 (or later)

B, D &T - Series Pressure Switches



80 N Main St
Sellersville, PA 18960